Drinking Water Quality and Compliance
Annual Notice to Consumers

Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to operate a waterworks. The following is a summary of the **Village of Fox Valley** water quality and sample submission compliance record for the **2025** period. This report was completed on March 23, 2026. Readers should refer to Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html .

Water Quality Standards
Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	24	31	0%
E. coli	0 Organisms/100 mL	24	31	0%

Water Disinfection –
Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.3 mg/L free OR 0.5 mg/L total	0.74-1.62	0.57-1.38	24	31	100%

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records- From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.42-1.48	365	0

A minimum of 0.1 milligrams per liter (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level # Tests Performed	Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	<1.0		0.16-0.64	0	0.64	365	365

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on (*May 14, 2024*). Sample results indicated that the provincial drinking water quality standards were not exceeded.

Saskatchewan Ministry of Environment

Water Security Agency

Parameter	Limit MAC (mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Arsenic	0.010		0.0024 mg/L		* Results expressed
Barium	1.0		0.0019 mg/L		as average values
Boron	5.0		0.4 mg/L		for communities or
Bromate	0.01		N/A		waterworks that
Cadmium	0.005		<0.00015 mg/L		fluoridate drinking
Chlorate	1.0		N/A		water supplies or
Chlorite	1.0		N/A		those with elevated
Chromium	0.05		<0.0019 mg/L		concentrations of
Fluoride (avg*)	1.5		0.23 mg/L		fluoride or nitrates.
Lead	0.01		<0.00007 mg/L		
Nitrate (avg.*)	45.0		<0.2 mg/L		
Selenium	0.01		<0.00113 mg/L		
Uranium	0.02		0.0138 mg/L		

General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	500	263	1	1
Bicarbonate	No Objective	321	1	1
Calcium	No Objective	117	1	1
Carbonate	No Objective	0	1	1
Chloride	250	28.1	1	1
Conductivity	No Objective	1495	1	1
Hardness	800	593	1	1
Magnesium	200	73	1	1
PH	No Objective	7.9	1	1
Sodium	300	121	1	1
Sulphate	500	561.1	1	1
Total dissolved Solids	1500	1127	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as $CaCO_3$), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required on (2024) and submitted on *May 14, 2024.* Sample results indicated that there were no exceedances of the provincial aesthetic objectives for the General Chemical category

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as $CaCO_3$, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

Village of Fox Valley, Renee Glass, Administrator
Box 207, Fox Valley, SK S0N 0V0
306-666-3020
villoffoxvalley@sasktel.net

June 2015 EPB 536D